

# Certificate of Compliance

Certificate: 1710842 (LR16325)

Master Contract: 172328

Project: 1710842

Date Issued: 2005/10/14


Issued to: Siemens AG

Installationstechnik-Abt Q MS  
Siemensstrasse 10  
Regensburg, 93055  
Germany  
Attention: Juergen Lang

*The products listed below are eligible to bear the CSA Mark shown*



Issued by: Steven Jeffrey



Authorized by: Gabriel Lipka, C.E.T., Product  
Group Manager



## PRODUCTS

**CLASS 1422 02 - FUSES - High Rupturing Capacity (HRC) Type**

High rupturing capacity non-renewable cartridge type fuses HRCII-Misc.600VAC,interrupting rating 100kA,Types 3NA68 and 3NA78 rated 32,35,40,50,63,80,100 and 125A;Types 3NA61 and 3NA71,size 1,35,40,50,63,80,100,125,160,200,224,250A;Types 3NA62 and 3NA72,size 2,80, 100, 125,160,200,224,250,300,315,355 and 400A

## APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No.106



## *Supplement to Certificate of Compliance*

**Certificate:** 1710842

**Master Contract:** 172328

*The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
1710842	2005/10/14	HRC Fuses